

CERTIFICATE

Issued to:
Applicant:
Pipelife Nederland B.V.
Flevolaan 7
1601 MA Enkhuzen, The Netherlands

Licensee:
Pipelife Nederland B.V.
Flevolaan 7
1601 MA Enkhuzen, The Netherlands

Product : Connection box for fixed electrical installations
Trade name(s) : PIPELIFE
Type(s)/model(s) : PL50 SW 1,5

The product and any acceptable variation thereto as specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to EN 60670-22:2006, EN IEC 60670-1:2021 and EN IEC 60670-1:2021/A11:2021
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 900427


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 10 May 2023 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-128119

DEKRA Certification B.V.




B.T.M. Holtus
Managing Director



R Zhou
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Connection box for fixed electrical installations
Trade name(s)	: PIPELIFE
Type(s)/model(s)	: PL50 SW 1,5
Ratings	: 16A / 240V ~
Material	: Polypropylene / PA 6 / PS
Spout	: Removable for conduits 16/19 mm

TESTS**Test requirements**

EN 60670-22:2006

EN IEC 60670-1:2021

EN IEC 60670-1:2021/A11:2021

Test result

The test results are laid down in DEKRA test file 227540500.

Conclusion

The examination proved that all requirements were met.

Factory location

Pipelife Nederland B.V.

Flevolaan 7

1601 MA Enkhuizen, The Netherlands