CERTIFICATE

Issued to: Applicant:

Pipelife Nederland B.V.

Flevolaan 7

1601 MA Enkhuizen, The Netherlands

Licensee:

Pipelife Nederland B.V.

Flevolaan 7

1601 MA Enkhuizen, The Netherlands

Product : Connecting box for fixed electrical installations

Trade name(s) : PIPELIFE Type(s)/model(s) : PL50 SW

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of

- a type test according to the standard(s) EN 60670-22:2006, EN IEC 60670-1:2021/and EN IEC 60670-1:2021/A11:2021
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 900427

DEKRA hereby grants the right to use the KEMA-KEUR certification mark

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 8 November 2022 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-125/180

DEKRA Certification B.V.

B.T.M. Holtus Managing Director

Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL











SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product : Connecting box for fixed electrical installations

Trade name(s) : PIPELIFE
Type(s)/model(s) : PL50 SW
Ratings : 16 A / 240 V ~

Material body / spout / cover : Polypropylene / PA 6 / PS

Spout : Removable for conduits 16/19 mm

Turnable ring : With 2 bolts M3

TESTS

Test requirements

EN 60670-22:2006 EN IEC 60670-1:2021

EN IEC 60670-1:2021/A11:2021

Test result

The test results are laid down in DEKRA test file 226924200.

Conclusion

The examination proved that all requirements were met.

Factory location

Pipelife Nederland B.V. Flevolaan 7 1601 MA Enkhuizen, The Netherlands