

# CERTIFICATE

Issued to:  
Applicant:  
**Preflexibel N.V.**  
**Elisabethlaan 153**  
**9400 Ninove, Belgium**

Licensee:  
**Preflexibel N.V.**  
**Elisabethlaan 153**  
**9400 Ninove, Belgium**

Product : Conduit systems for cable management  
Trade name(s) : PREFLEX or PREFLEXIBEL  
Type(s)/model(s) : PRF16, PRF 20, PRF 25, PRF 32 and PRF 40

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN 61386-1:2008, EN 61386-1:2008/A1:2019, EN IEC 61386-22:2021 and EN IEC 61386-22:2021/A11:2021
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 990167


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 28 May 2025 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2166577.01 REV.1

DEKRA Certification B.V.



B.T.M. Holtus  
Managing Director



Miranda Zhou  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: Conduit systems for cable management
Trade name(s)	: PREFLEX or PREFLEXIBEL
Type(s)/model(s)	: PRF 16, PRF 20, PRF 25, PRF 32 and PRF 40
Tested conduits	: PRF 16 pliable self recovering PRF 20 pliable self recovering
Certified conduits	: PRF 16 pliable self recovering PRF 20 pliable self recovering PRF 25 pliable self recovering PRF 32 pliable self recovering PRF 40 pliable self recovering
Classification	: 3422
Type	: Pliable, self recovering
Method of connection	: Non-treadable
Flame propagation	: Non flame propagation
Colours	: All colours except red, orange and yellow

**TESTS****Test requirements**

EN 61386-1:2008  
EN 61386-1:2008/A1:2019  
EN IEC 61386-22:2021  
EN IEC 61386-22:2021/A11:2021

**Test result**

The test results are documented in DEKRA test file 216657700, 229978100.

**Additional information**

Additional information : CLASSIFICATION CODING

First digit : 3 Medium compression strength 750 N.  
Second digit : 4 Heavy impact strength 2 kg/300 mm.  
Third digit : 2 Minimum permanent application - 5°C and installation temperature.  
Fourth digit : 2 Maximum permanent application + 90°C and installation temperature.  
Fifth digit : 3 Resistance to bending Pliable/self-recovering.

This certificate replaces certificate No. 2166577.01 which we hereby declare invalid.

**Conclusion**

The examination has confirmed that all requirements were met.

**Factory locations**

Preflexibel N.V.  
Elisabethlaan 153  
9400 Ninove, Belgium

Preflex France  
500 Avenue du Moulinas  
30340 Salindres, France