

LICENCE

No. 19644

Issued to:
 Applicant:
Pipelife Nederland B.V.
Flevolaan 7
1601 MA ENKHUIZEN
Netherlands

Licensee:
Pipelife Nederland B.V.
Flevolaan 7
1601 MA ENKHUIZEN
Netherlands



Product : conduit systems for cable management
 Trade name(s) : POLVALIT UVS
 Type(s)/model(s) : Conduits M16 , M20 Low Friction, Conduits M25 , M32 , M40 and M50


The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 68

SGS CEBEC hereby grants the right to use the CEBEC certification mark
 The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 07/09/2015



ir. C. Lana,
 Certification Manager

© Only integral publication of this certificate, including the annex, is allowed
 This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee



SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	conduit systems for cable management
Trade name(s)	:	POLVALIT UVS
Type(s)/Model(s)	:	Conduits M16 , M20 Low Friction, Conduits M25 , M32 , M40 and M50
type of conduit (1)	:	non-metallic
type of conduit (2)	:	classification 3-4-4-1
type of conduit (3)	:	plain
method of connection	:	non-threadable
resistance to compression	:	medium
resistance to impact	:	heavy
resistance to bending	:	rigid
lower temperature range	:	-25°C
upper maximum temperature range	:	+60°C
electrical characteristics	:	with electrical insulating
resistance to flame propagation	:	non-flame propagation
colour(s)	:	black RAL 9005

TESTS

Test requirements

NBN EN 60423 based on EN 60423:2007
NBN EN 61386-1 based on EN 61386-1:2008
NBN EN 61386-21 based on EN 61386-21:2004 + A11:2011

Test results

The test results are laid down in certification file ref.611640/02

Remarks

This certificate is based on certificate ref. NTR NL 7331 and test reports ref. 2176001.51


Conclusion

The examination proved that all test requirements were met.

Checked by, project leader : Zanutto Luigi - 07/09/2015

Department Manager,
Product Certification :

Certification Manager :



Zanutto 2015-09-07

FACTORY LOCATION(S)

Pipelife Nederland B.V.
Flevolaan 7
1601 MA ENKHUIZEN
Netherlands